



SANITARY CERTIFICATE

H9/5883/2020(Main)

Tiruchirappalli City Corporation,
Dated:23.12.2020

This is to certify that the accommodation provided for of the several room and toilets are sufficient for the pupils there in and is properly ventilated and lighted, the buildings are maintained in substantial repair that they are neat supply of drinking water is wholesome and that in all other necessary aspects and sanitation is satisfactory.

The above certificate is issued subject to the following Conditions.

01. The Garbage generated within the premises should be collected and disposed by onsite compost within the premises as per Municipal Solid waste Management rules 2016.
02. On any account the Garbage should not be burnt, on violation a spot fine of Rs.1000 will be imposed.
03. The Pupils should be educated to prevent the usage of plastics in the premises and no one should bring plastic carry bags, plastic disposable tumblers to the premises.
04. Fire precautionary measures and First aid box should be maintained properly.
05. As per Tamil Nadu COVID – 19 Standard Operating Procedure there should be a proportionate numbers of hand washing facility **with soap & water** at the entrance of the premises & Social distancing, wearing mask should be ensured at all time within the premises.
06. Child Labour should not be engaged on any account.
07. Should not cause nuisance to the health of the public as per definition under **Tamil Nadu Public Health act 1939**.
08. Cigarette or any other tobacco product should not be used inside the campus as per the rule under **COTPA Act 2003**.
09. A Sign board should be displayed in front of the school mentioning **“TOBACCO PRODUCT SALE”** is prohibited within 100 yards radius around school campus.
10. The campus must be kept **free of Aedes breeding to avoid incurring fine** and or legal action.
11. The issued Certificate is valid for **one year** only from the date of issue.
12. This Certificate issued is liable to be cancelled at anytime on infringement of any this condition and for improper maintenance of the building as well as the toilet in the institute.

Sanitary Inspector / Officer,
Tiruchirappalli City Corporation.

City Health Officer,
Tiruchirappalli City Corporation.

To

THE PRINCIPAL,
MONTFORT SCHOOL (CBSE)
KATTUR,
TIRUCHIRAPPALLI.

PRINCIPAL & CORRESPONDENT
MONTFORT SCHOOL
KATTUR, TRICHY 620019.





DEPARTMENT OF PUBLIC HEALTH AND PREVENTIVE MEDICINE
Regional Public Health Water Analysis Laboratory, Tiruchirappalli-20.

From
Thiru.G.Subramanian, M.Sc., M.Ed.,B.L.,
Chief Water Analyst (i/c),
Regional Public Health Water Analysis
Laboratory, Tiruchirappalli- 20.
Telephone No.0431-2332570

To
The Principal,
Montfort School, Kattur,
Tiruchirappalli-620 019.

R.No.839/A3/2020/CWA/TRY/Misc- 245, Dated: 15.10.2020

Sir,

Sub: Report on examination of water samples from Montfort School,
Kattur, Trichy-19 – Collected on 12.10.2020.

A sample of water stated to have been collected on 12.10.2020 from the Borewell at Montfort School, Kattur, Trichy-19 by Thiru.Mathias, Driver was received at this laboratory on the same day to assess its suitability for drinking purpose.

The results of analysis are furnished overleaf.

The sample of water is colourless and clear in physical appearance.

Chemically, it is of very hard in nature and highly mineralized. However, it is of tolerable quality for drinking.

Bacteriologically, it is of satisfactory quality for drinking.

M 15-10-2020
Chief Water Analyst, (i/c)

Regional Public Health Water Analysis
Laboratory, Tiruchirappalli-20.

Copy to:

1. Lab
2. File.

A. Praveen
PRINCIPAL & CORRESPONDENT
MONTFORT SCHOOL
KATTUR, TRICHY 620019.

PRINCIPAL & CORRESPONDENT
MONTFORT SCHOOL
KATTUR, TRICHY 620019

RESULTS OF EXAMINATION OF SAMPLES OF WATER

From : Montfort School, Kattur, Trichy-19.

Collected by:- Thiru.Mathias, Driver.

Date of collection	12.10.2020			
Date of Receipt	12.10.2020			
Sample Number	M- 245			
Source as per label [Cauvery]	Directly from Borewell			
<u>Bacteriological Examination</u>				
Total colonies per ml. On agar at 37°C	-0-			
MPN of Coliform bacteria per 100ml.	-0-			
Rapid Test for E.Coli-1				
<u>Physical Examination</u>				
Colour	Colourless			
Turbidity	5			
Smell	None			
Total solids	920			
Carbonate hardness as CaCO ₃	432			
Non-Carbonate hardness as CaCO ₃	160			
Total hardness as CaCO ₃	592			
Chlorides as Chlorine	300			
Ammoniacal nitrogen Directness	--			
Albuminoid nitrogen	--			
Oxygen absorbed (Tidy's test)	0.32			
Nitrate -nitrogen	0.5			
Acidity/Alkalinity Phenolphthalein sCaCO ₃ Methyl Orange	0			
	368			
Fluoride as Fluorine	0.2			
pH Value	6.7			
Iron as Fe	0.1			
Ferrous	--			
Manganese as Mn.	--			
Nitrite nitrogen	Trace			
Sulphate	Trace			
Phosphate	Trace			
Toxic substance	--			
Electrical conductivity (Reciprocal megohms per cm ³ at 20 C)	1310			
Microscopical Examination	Amorphous matter			


PRINCIPAL & CORRESPONDENT
MONTFORT SCHOOL
KATTUR, TRICHY 620019.